



39

586
L.Dis.No. 7068 /A5/2022

O/o the Deputy Director of Health Services,

Tenkasi.

Date: 30.11.2022

SANITARY CERTIFICATE FOR THE EDUCATIONAL INSTITUTIONS

BLOCK : KEELAPAVOOR

DISTRICT : TENKASI

THE TAMILNADU EDUCATIONAL RULE 24 & APPENDIX-3


(Form of Sanitary Certificate)

CERTIFICATE

Year 2022-2023


I hereby declare that I have caused to be inspected the **WONDER SCHOOL, TENKASI AMBAI, STATE HIGHWAY, WONDER NAGAR, THIRAVIYA NAGAR** Building and Premises on **07.11.2022** and certify that the accommodation provided for each of the several classes is sufficient for the maximum number of pupil taught therein and is properly ventilated and lighted, that the building is maintained in substantial repair, that it is neat and clean, that the latrine arrangements are adequate and satisfactory, that the supply of drinking water is good, and that in all other necessary aspects the sanitation is Good.


This certificate is valid from June 2022 to May 2023


BLOCK HEALTH SUPERVISOR
GOVT PRIMARY HEALTH CENTRE
PAVOORCHATRAM
KEELAPAVOOR BLOCK
TENKASI DISTRICT


Countersigned based on the inspection report of


Block Health Supervisor of the concerned block Dt. 07.11.2022



DEPUTY DIRECTOR OF
HEALTH SERVICES
TENKASI - 627 811.



CORRESPONDENT
Wonder School
Wonder Nagar

Thippanamatti - 627 808
Tenkasi - Ambai State Highway
Tenkasi (Tk), Tenkasi (Dist)


PRINCIPAL
WONDER SCHOOL
TENKASI - AMBAI STATE HIGHWAY
WONDER NAGAR
THIPPANAMPATTI
TENKASI - 627 808


30/11/2022


30.11.22


30/11/22



TEST WATER BEFORE TASTE
TAMIL NADU WATER SUPPLY & DRAINAGE BOARD
 District Level Water Testing Laboratory, Tirunelveli
 Seevalperi road, Santhi nagar, Palayamkottai -627002 - Ph:0462-2542576

TEST REPORT

From
 K. Rengaraj M.Sc., M.Phil.,
 Junior Water Analyst, TWAD Board,
 District Water Testing Laboratory,
 Tirunelveli.

To
 Correspondent Wonder School,
 Thippanampatti-627808
 Tenkasi-Ambai State Hiway,
 Tenkasi.

Lr.No.54042-54043/ JWA/Lab /TNLY /19-20/Dated 06.02.2020

Sir,

Sub : Examination of water sample - Report furnished - Reg.
 Ref: 1) Lr.No. Nil/dt 3.02.2020.
 2) Our Invoice No.8958/Dated 3.02.2020 for Rs 1652/-
 3) IOB ,Tvl, DD NO 746692 / dt 3.02.2020 For Rs 1652/-

The result of analysis for the water sample sent under reference is furnished below.

Scheme : Wonder School

Source : Bore Well.

Location: Wonde School, Thippanampatti.


Date of Collection : 03.02.2020

Date of Receipt : 03.02.2020

BIS 10500 : 2012	Acceptable limit	Permissible limit in the absence of alternate source	Result
I. PHYSICAL EXAMINATION.			54042
1. Appearance	-	-	clear
2. Colour	Agreeable	Agreeable	colourless
3. Odour	-	-	None
4. Turbidity NT Units	1	5	0
5. Total dissolved Solids mg/L	500	2000	844
6. Electrical Conductivity Micro mho/cm	-	-	1241
II. CHEMICAL EXAMINATION:			
7. pH	6.5-8.5	6.5-8.5	7.17
8. Ph. Alkalinity as CaCO ₃ mg/L	-	-	0
9. Total Alkalinity. as CaCO ₃ mg/L	200	600	400
10. Total Hardness as CaCO ₃ mg/L	200	600	460
11. Calcium as Ca mg/L	75	200	120
12. Magnesium as Mg mg/L	30	100	38
13. Sodium as Na mg/L	-	-	80
14. Potassium as K mg/L	-	-	12
15. Iron as Fe mg/L	0.3	1	0.00
16. Manganese mg/L	0.1	0.3	-
17. Free Ammonia as NH ₃ mg/L	0.5	0.5	0.00
18. Nitrite as NO ₂ mg/L	-	-	0.01
19. Nitrate as NO ₃ mg/L	45	45	5
20. Chloride as Cl mg/L	250	1000	116
21. Fluoride as F mg/L	1.0	1.5	0.2
22. Sulphate as SO ₄ mg/L	200	400	53
23. Phosphate as PO ₄ mg/L	-	-	0.23
24. Tidy's Test 4 hrs. as O ₂ mg/L	-	-	0.24
III. BACTERIOLOGICAL EXAMINATION			54043
25. Fecal coliform per 100 ml.	Nil/100ml	Nil/100ml	0

Report: Lab No:-54042 : The water is chemically potable.

Report: Lab No:-54043 : The water is bacteriologically safe


 Junior Water Analyst
 TWAD Board, D.W.T. Laboratory
 Tirunelveli